

# Apollo Flooring Systems Ltd

## Control of Substances Hazardous to Health (COSHH)

### Regulation 6

Degadur 526 Sealer

Carried out by:

Signature .....

K Brown  
Occupational Health & Safety Adviser

Date ..30 October 2007.....

### Process

Degadur 526 Sealer is applied to the Resin after curing using sheep-skin rollers and paintbrushes.

Two coats are applied, each one being allowed to cure for 30 minutes.

. The area in which the floor is to be laid will be sealed using visqueen sheeting and forced exhaust ventilation will be in operation.

### Requirements for controlling exposure

	Yes	No
Education, training, or instruction	x	
Specific control procedures		x
Extract ventilation	x	
Exposure monitoring		x
Health surveillance		x
Personal protective equipment	x	

**Overall assessment statement**

Degadur 526 Sealer contains methyl methacrylate and 2-ethylhexyl acrylate, which will cause irritation if in contact with the skin or eyes. It may cause sensitisation of the skin. Impermeable gloves and goggles must be worn when mixing and handling the substance.

It is also an irritant to the respiratory system. Respiratory masks must be worn to prevent inhalation when using and applying.

Hands must be thoroughly washed after handling the substance to prevent ingestion.

If the above conditions are met, the level of risk will be reduced to low.

In the event of contact with the skin, the area(s) should be thoroughly washed with soap and water. Medical attention should be sought if irritation occurs.

In the event of contact with the eyes, they should be flushed in copious amounts of water, preferably running water, immediately and medical attention sought.

In the event of inhalation, the victim must be moved to fresh air immediately, kept calm and medical attention summoned.

The substance is highly flammable and must be kept well away from all sources of heat. In the event of fire, the fire brigade should be called immediately. Self-contained breathing apparatus must be worn when tackling fires containing the substance.

The product should not be allowed to enter drains, surface or ground water.

Supplier safety data sheet obtained?	Yes / No
	x
Name of supplier	.....degussa Rohm Speciality Acrylics.....

This assessment is valid on the date shown above. It must be reviewed when any of the following takes place:

- ÿ change of material
- ÿ change of supplier
- ÿ change in process
- ÿ change in method of working